

Certificate of Product Approval

Certificate Number: 1410a

Issue: 01

CLEVELAND CABLE COMPANY

Riverside Park Road
Middlesbrough
Cleveland
TS2 1QW



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
ZFLAM200
See Certificate Appendix for details

Standard(s) (see Appendix for details)

BS 6387:2013 (CWZ)
EN 50267-2-1:1999
EN 61034-2:2005+A1:2013
EN 50200:2006 Annex E (30 mins)
EN 50200:2006 (Class PH120)
EN 60332-3-24:2009
EN 60332-3-25:2009

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Karen Coull
Certification Scheme Manager

25 May 2017
Date of Issue

25 May 2017
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 1410a CLEVELAND CABLE COMPANY

Issue: 01

Product name						LPCB Ref. No.
ZFLAM200						1410a/01
Nominal csa of conductor (mm ²)	Core Construction (excluding drain wire and earth)	BS 6387	EN 50267-2-1	EN 61034-2	EN 50200 Annex E	EN 50200
0.5 ⁽¹⁾	2, 3 & 4	C,W,Z	<0.5% HCl	>60%	30min ⁽³⁾	Class PH120
0.75 ⁽¹⁾	2, 3 & 4	C,W,Z	<0.5% HCl	>60%	30min ⁽³⁾	Class PH120
1.0 ⁽¹⁾	2, 3 & 4	C,W,Z	<0.5% HCl	>60%	30min ⁽³⁾	Class PH120
1.5 ⁽¹⁾	2, 3 & 4	C,W,Z	<0.5% HCl	>60%	30min ⁽³⁾	Class PH120
2.5 ⁽¹⁾	2, 3 & 4	C,W,Z	<0.5% HCl	>60%	30min ⁽³⁾	Class PH120
4.0 ⁽²⁾	2, 3 & 4	C,W,Z	<0.5% HCl	>60%	30min ⁽³⁾	Class PH120

Uo/U 300/500V

Notes:

1. Solid conductor only.
2. Stranded conductor only.
3. The duration of 30 min when tested in accordance with EN 50200: 2006 Annex E is achieved by 15 min for the fire and mechanical shock phase and a further 15 min for the fire mechanical shock and water phase.
4. Where the cable diameter is greater than 12mm the cable is additionally approved to EN 60332-3-24.
5. Where the cable diameter is equal to or less than 12mm the cable is additionally approved to EN 60332-3-25.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Karen Coull
Certification Scheme Manager

25 May 2017
Date of Issue

25 May 2017
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com


